

**PROFORMA REGARDING SAFE DRINDING WATER AND SANITARY
CONDITION CERTIFICATE**

No. 2090

Date: 21/05/2025

It is certified that an inspection team headed by Deputy Cmo G.B. Nagar. **M.S. Public Junior High School, Vidhya Vihar Colony Near Talab, Chipiyana, G.B Nagar.** on dated 20-05-2025 and found that the **M.S. Public Junior High School** has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T. Govt.

The above valid for a period of 1 Year.

Signature with Seal:-  

Name:- Dr. Narendra Kumar


Designation:- Chief Medical Officer

To

The Principal,
M.S. Public Junior High School
Vidhya Vihar Colony Near Talab, Chipiyana
Gautam Budh Nagar.


प्रबन्धक

एम.एस. पब्लिक जूनियर हाई स्कूल
चिपियाना बुजुर्ग-गौतम बुद्ध नगर


प्रधानाचार्य

एम.एस. पब्लिक जूनियर हाई स्कूल
चिपियाना बुजुर्ग-गौतम बुद्ध नगर



OFFICE OF THE EXECUTIVE ENGINEER GANGA JAL PROJECT UNIT,
U.P. JAL NIGAM (URBAN) 120 MLD W.T.P. LABORATORY,
PRATAP VIHAR, GHAZIABAD-201009

Letter No. 1426 /

२९२५

135

Dated 11.09.2025

To,

Principal

M. S. Public Junior High School
Vidhya Vihar Colony Near Talab, Chipyana
Gautam Budh Nagar.

Sub :- **Physical and Chemical analysis of water sample**

Dear Sir

The water analysis report for the water sample (01 No.) sent along with your letter No. 292 / 25 Dated 04.09.2025 the physical and chemical analysis report is enclosed with this letter.

Drinking Water Sample From M.S. Public Junior High School :- 1 No.
Vidhya Vihar Colony Near Talab, Chipyana
Gautam Budh Nagar.


Total :- 1 No.

Enclosers : As Above.


Executive Engineer


प्रबन्धक

एम.एस. पब्लिक जूनियर हाई स्कूल
चिपियाना बुर्ज-गौतम बुद्ध नगर


प्रधानाचार्य
एम.एस. पब्लिक जूनियर हाई स्कूल
चिपियाना बुर्ज-गौतम बुद्ध नगर



WATER TESTING LABORATORY

120 MLD, WATER TREATMENT PLANT, GANGA JAL PROJECT,
PRATAP VIHAR, GHAZIABAD- 201009



TEST REPORT

TC-15179

Lab Address	120 MLD Water Treatment Plant Ganga Jal Project, Pratap Vihar, Ghaziabad				
Customer Name and Address	M.S. Public Junior High School Vidhya Vihar Colony Near Talab, Chipyana Gautam Budh Nagar.	Lab Temperature During Testing	27.7°C		
Test Report No.	UPJN/2025-26/B/062	Test Start Date:	04.09.2025		
Sample Description	Drinking Water Sample From M.S. Public Junior High School Vidhya Vihar Colony Near Talab, Chipyana Gautam Budh Nagar.	Test Completion Date:	06.09.2025		
Specification	IS 10500:2012 Amendment No. 2	Issued Date:	06.09.2025		
Sample Packaging Details	Sample Sealed (01 Litres)	Sample code	UPJN/2025-26/B/062		
Environment conditions at Lab During Testing	25°C ± 3°C				
Sr. No.	Test Parameters/ Unit	Test Result	Requirement as Per IS 10500:2012		Test Method
			Acceptable Limit	Permissible Limit	
1	pH	7.16	6.50 - 8.50	No Relaxation	IS: 3025 Pt-11:2022
2	Turbidity, NTU	0.29	1.0	5.0	IS: 3025 Pt-10:2024
3	Total Hardness (as CaCO ₃) mg/l	36.00	200	600	IS: 3025 Pt-21:2023
4	Calcium (as Ca) mg/l	6.41	75	200	IS: 3025 Pt-40:2024
5	Magnesium (as Mg) mg/l	4.05	30	100	IS: 3025 Pt-46:2023
6	Chloride (as Cl) mg/l	26.94	250	1000	IS: 3025 Pt-32:2019
7	Total Dissolved Solids, mg/l	78.00	500	2000	IS: 3025 Pt-16:2023
8	Total Solids, mg/l	92.00	--	--	IS: 3025 Pt-15:2009
9	Conductivity, µS/cm	124.00	--	--	IS: 3025, Pt-14:2019

DECLARATION:

- This test report refers to items submitted for testing only.
- This test report shall not be re-produced except in full unless written permission for the publication of an approved abstract has been obtained from WTL.
- The test results reported in this report are valid at the time and under the stated conditions of testing
- Sampling is not done by WTL Sample is provided by the customer.

— End of Report —

Reviewed By:

Name: Hari Sharan

Designation: Chemist

Doc. NO. WTL/F/TR/01, Rev- 00

प्रबन्धक

Authorized Signatory

Name: Kishan Singh Adhikari

Designation: Technical Head

Page-1 of 1

प्रधान अचार्य
एम.एस. पब्लिक जूनियर हाई स्कूल
चिपियाना बुजुर्ग-गौतम बुद्ध नगर



120 MLD WATER TREATMENT PLANT LAB

U.P. JAL NIGAM, GHAZIABAD

TRNo. 002179

Letter No. - 1426

Testing

1 135

Dated : 11/09/2025

DRINKING WATER ANALYSIS REPORT

Sample Sealed	:	Yes
Name of person Collected Sample	:	Sh. Sudarshan Singh
Date & Time of Sample Collection	:	04.09.2025
Particulars/Source of Sample	:	Drinking Water Sample From M.S. Public Junior High School Vidhya Vihar Colony Near Talab, Chipyana Gautam Budh Nagar.
Date of receipt of sample at Lab	:	04.09.2025
Sender Ref. No.	:	292 / 25 Dated 04.09.2025
By	Principal	M.S. Public Junior High School Vidhya Vihar Colony Near Talab, Chipyana Gautam Budh Nagar.
Laboratory analysis Ref. No.	:	PC-3921 Date: 06.09.2025

Test Results: Physico-Chemical Characteristics As per IS 10500 : 2012 as Amendment

No. 2



Sl.No.	Characteristic	Expressed as	Analysed result	Acceptable limit	Permissible limit
1	2	3	4	5	6
1	Sulphate (as SO ₄)	mg/l	09.00	200	400
2	Fluoride (as F)	mg/l	0.16	1.0	1.5
3	Nitrate (as NO ₃)	mg/l	BDL	45	No relaxation
4	Iron (as Fe)	mg/l	BDL	1.0	No relaxation
5	Residual Chlorine	mg/l	Nil	0.2	1.0

Note :- (i) Figures in Col-5 are the limits up to which drinking water is acceptable to the consumers.
(ii) Figures in excess of Col-6 render the water not acceptable, but still may be tolerated
(up to the limit indicated in the Col-6) in the absence of alternative and better source.
(iii) The water sample is not collected by us.
(iv) BDL- Below Detection Limit.


Test Conducted By


(For M/S Pooja Construction Co.)

COUNTER SIGNED BY


J. E. 
A.E.
प्रबन्धक

Executive Engineer


प्रधानाचार्य
एम.एस. पब्लिक जूनियर हाई स्कूल
चिपियाना बुजुर्ग-गौतम बुद्ध नगर

एम.एस. पब्लिक जूनियर हाई स्कूल
चिपियाना बुजुर्ग-गौतम बुद्ध नगर

Office of The Project Manager, Ganga Jal Project Unit
U.P. Jal Nigam, Pratap Vihar, Ghaziabad

Telefax - 120-2746494, Ph.: 7599201512, E-mail : pmgangajalgzb@yahoo.com